

ATTENTION OWNER: Confidentiality
 Privilege Notice on an reverse side
 of Well Owner's copy (pink)

State of Texas WELL REPORT

Texas Water Well Drillers Advisory Council
 MC 177
 P.O. Box 13087
 Austin, TX 78711-3087
 512-239-0530

1) OWNER Gary Page (Name) ADDRESS 1907 Omar Cibolo, Texas 78108
 (Street or RFD) (City) (State) (Zip)
 2) ADDRESS OF WELL: Kendall 216 Walnut Rd Comfort, TX 78013 57-58-3
 County (Street, RFD or other) (City) (State) (Zip) GRID #

3) TYPE OF WORK (Check):
 New Well Deepening
 Reconditioning Plugging
 4) PROPOSED USE (Check): Monitor Environmental Soil Boring Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
 If Public Supply well, were plans submitted to the TNRCC? Yes No

5) WELL LOG:
 Date Drilling: _____
 Started 02-27-97
 Completed 03-04-97
 6) DIAMETER OF HOLE

Dia. (in.)	From (ft.)	To (ft.)
8 1/2"	Surface	510'

 7) DRILLING METHOD (Check): Driven
 Air Rotary Mud Rotary Bored
 Air Hammer Cable Tool Jetted
 Other _____

8) Borehole Completion (Check): Open Hole Straight Wall
 Underreamed Gravel Packed Other _____
 If Gravel Packed give interval ... from _____ ft. to _____ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
5 1/2"		SDR 17 pvc casing	0	408	
		total 410'			

9) CEMENTING DATA [Rule 338.44(1)] 3.50 yards total
 Cemented from 0 ft. to 410 ft. No. of sacks used _____
 _____ ft. to _____ ft. No. of sacks used _____
 Method used H. W. Schwope & Sons, Inc.
 Cemented by 8-sk grout
 Distance to septic system field lines or other concentrated contamination _____ ft.
 Method of verification of above distance _____

10) SURFACE COMPLETION
 Specified Surface Slab Installed [Rule 338.44(2)(A)]
 Specified Steel Sleeve Installed [Rule 338.44(3)(A)]
 Pileless Adapter Used [Rule 338.44(3)(b)]
 Approved Alternative Procedure Used [Rule 338.71]

11) WATER LEVEL:
 Static level 275 ft. below land surface Date _____
 Artesian flow _____ gpm. Date _____

12) PACKERS:

Type	Depth

13) TYPE PUMP:
 Turbine Jet Submersible Cylinder
 Other 1 1/2 hp Goulds (12SB15) 380' 1 1/4" #80 pv
 Depth to pump bowls, cylinder, jet, etc., _____ ft. 21' 1 1/4" galv pipe
 14) WELL TESTS:
 Type test: Pump Bailer Jetted Estimated
 Yield: 70-80 gpm with _____ ft. drawdown after _____ hrs.
 15) WATER QUALITY:
 Did you knowingly penetrate any strata which contained undesirable constituents?
 Yes No If yes, submit "REPORT OF UNDESIRABLE WATER"
 Type of water? _____ Depth of strata _____
 Was a chemical analysis made? Yes No

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME H. W. Schwope & Sons, Inc. WELL DRILLER'S LICENSE NO. 1568
 (Type or print)
 ADDRESS P. O. Box 364 Boerne, TX 78006
 (Street or RFD) (City) (State) (Zip)
 (Signed) George Schwope (Signed) _____
 (Licensed Well Driller) (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.